

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITIONCERTIFICATENo. 2082Date: 20/7/2026It is certifies that an inspection team headed by MAHENDRA SAINI (A.S.I)
(Name of Officers withdesignation) from Municipal Board mukundgarh (Name of Department/Office) inspected theGurukul Public School viii - Gosivara/Rhurd Teh - Nawalgarh
(Name and address of the school) on _____ and found that theGurukul Public School viii - Gosivara/Rhurd Teh - Nawalgarh
(Name of school) has safe drinking water facilities for the students and members of staff of the institution
and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T. Govt.The above valid for a period of 6 month.Signature: पूनाम चन्द नाई
नगरपालिका मुकुन्दगढ़Name: Poonam chand NaiDesignation: Executive officerTo Secretary
Gurukul Public School
Teh. Nawalgarh (JTN)
Raj

(Name and Address of the Institution)



PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU
CHEMICAL EXAMINATION REPORT OF WATER

Date - 1-7-2026

No. Lab. / Chem. /2026-27/ 216

To,
Chairman
Gurukripa Public School
Ghoriwara Khurd (Nawalgarh)
Ref- Your letter no.GPS/111/2026-27 dated 01.07.2026

District - Jhunjhunu
Tehsil - Nawalgarh
Date of Exam - 01-07-2026

A	Name & Location of Source	IS-10500:2012		Water Sample Gurukripa Public School
B	Village/ Town			Ghoriwara Khurd
C	Date Of Collection			01-07-2026
D	Lab. Sample No.			C-081
Sr. No	Parameters	Desirable limits	Permissible limits	Value
1	pH	6.5—8.5	6.5—8.5	7.85
2	Turbidity[NTU]	1	5	Nil
3	Temperature[C]	-----	-----	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.
6	Residual Chlorine	0.2	1.0	Nil
7	Total Alkalinity[asCaCO ₃]	200	600	300
8	Total Hardness[asCaCO ₃]	200	600	150
9	Chloride[asCl ⁻¹]	250	1000	150
10	Nitrate[as NO ₃ ⁻¹]	45	45	29
11	Fluoride [as F ⁻¹]	1.0	1.5	0.62
12	Sulphate [as SO ₄ ⁻²]	200	400	24
13	TDS	500	2000	680

Note:1- All Results Except pH in mg/L.

2- This report is not valid for legal cases/legal purposes.


(S K Sharma)
Junior Chemist
PHED Laboratory Jhunjhunu